Report #:DOE/EIA-0554(2009)
Release date: March 2009
Next release date: March 2010

Assumptions to the Annual Energy Outlook 2009

Table 4.2. Installed Cost and Efficiency Ratings of Selected Equipment

Equipment Type	Relative Performance[1]	2007 Installed Cost ($2007)[2]	Efficiency[3]	2020 Installed Cost ($2007)[2]	Efficiency[3]	Approximate Hurdle Rate
Electric Heat Pump	Minimum	$3,800	13.0	$3,800	13.0	15%
	Best	$6,700	17.0	$6,700	20.0	
Natural Gas Furnace	Minimum	$1,900	0.80	$1,900	0.80	15%
	Best	$3,050	0.96	$2,700	0.96	
Room Air Conditioner	Minimum	$310	9.8	$310	9.8	140%
	Best	$925	11.7	$875	12.0	
Central Air Conditioner	Minimum	$3,000	13.0	$3,000	13.0	15%
	Best	$5,700	21.0	$5,750	23.0	
Refrigerator (23.9 cubic ft in adjusted volume)	Minimum	$550	510	$550	510	19%
	Best	$950	417	$1000	417	
Electric Water Heater	Minimum	$400	0.90	$400	0.90	30%
	Best	$1,400	2.4	$1,700	2.4	
Solar Water Heater	N/A	$3,500	2.0	$4,000	2.0	30%

[1]Minimum performance refers to the lowest efficiency equipment available. Best refers to the highest efficiency equipment available.

[2]Installed costs are given in 2007 dollars in the original source document.

[3]Efficiency measurements vary by equipment type. Electric heat pumps and central air conditioners are rated for cooling performance using the Seasonal Energy Efficiency Ratio (SEER); natural gas furnaces are based on Annual Fuel Utilization Efficiency; room air conditioners are based on Energy Efficiency Ratio (EER); refrigerators are based on kilowatt-hours per year; and water heaters are based on Energy Factor (delivered Btu divided by input Btu).

Source: Navigant Consulting, *EIA Technology Forecast Updates*, Reference Number 20070831.1September 2007.