

Biomass for Electricity Generation

Table 8. Assumed Maximum Co-firing Limits by Region in the AEO2002 Reference Case
(Percent)

NERC Region ^a	Co-firing Limit	NERC Region ^a	Co-firing Limit	NERC Region ^a	Co-firing Limit
ECAR	4.67	NPCC/NY	5.00	SPP.....	4.27
ERCOT	4.24	NPCC/NE	5.00	NWP	2.48
MAAC	3.28	SERC/FL.....	5.00	WRA	5.00
MAIN	5.00	SERC	3.62	CNV	0.00
MAPP	3.67				

^aNorth American Electric Reliability Council (NERC) regions: ECAR, East Central Area Reliability Coordination Agreement; ERCOT, Electric Reliability Council of Texas; MAAC, Mid-Atlantic Area Council; MAIN, Mid-America Interconnected Network; MAPP, Mid-Continent Area Power Pool; NPCC/NY, Northeast Power Coordinating Council/New York; NPCC/NE, Northeast Power Coordinating Council/New England; SERC/FL, Southeastern Electric Reliability Council/Florida; SERC, Southeastern Electric Reliability Council (Excluding Florida); SPP, Southwest Power Pool; NWP, Northwest Power Pool; WRA, Rocky Mountain Power Area; CNV, California-Southern Nevada Power.

Source: Energy Information Administration, Office of Integrated Analysis and Forecasting.